

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1209:104

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 FAX (630) 377-7245

DESIGN: Models listed below:

M500M, M501M	Monitor Modules
M500R, M500S, M500MB	Control Modules
M500C, M500CH, M502M	Control Modules
M500X	Fault Isolator Module
A2143-00	End-of-line Resistor
SMB500	Surface Mount Box
RMK400	Recessed Mounting Kit
MB500	Module Panel
CB500	Barrier Module
*EOLR-1	End-of-Line Supervision Relay

Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. Model SMB500 surface mount box may be used as an enclosure for the Model M500M monitor module, Models M500C or M500CH control module or Module M500X fault isolator module. Model A2143-00 end-of-line resistor is intended for use in the initiating circuit of the M500M and the indicating circuit of the M500C. Model RMK400 mounting kit is intended for use with separately listed compatible smoke detectors. Refer to listee's Installation Instruction Manual for details.

*Rev. 11-19-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 19, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**